



- GENERAL NOTES**
- A. ALL FIBER OPTIC CABLES ARE TO BE ROUTED IN 1" EMT CONDUIT ORANGE IN COLOR, NO LP'S OR CONDUIT BODIES ARE ALLOWED. PROVIDE MINIMUM 12"x12" J-BOXES WHERE REQUIRED. ALL J-BOXES TO BE ORANGE IN COLOR AND TO BE STENCILED "ENGINEERING FIBER OPTIC".
  - B. PROVIDE ALL CUTTING AND PATCHING (INCLUDING FIRE STOPPING) OF FLOORS, WALLS, OR CEILINGS REQUIRED FOR THE FIRE ALARM SYSTEM, MATCH ADJACENT SURFACES.
  - C. THESE DRAWINGS SHOW THE GENERAL LOCATIONS OF EXISTING FIRE ALARM CONTROL PANELS AND REMOTE FIRE ALARM ANNUNCIATORS. THE CONTRACTOR SHALL REMOVE ALL EXISTING CONTROL PANELS, ANNUNCIATORS AND ASSOCIATED FIRE ALARM NETWORK CONTROL COMPONENTS AND REPLACE WITH NEW ADDRESSABLE FIRE ALARM CONTROL PANELS. REMOTE FIRE ALARM ANNUNCIATORS AND ASSOCIATED COMPONENTS AS SHOWN ON THESE DRAWINGS AND OUTLINED IN THE SPECIFICATIONS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR DETERMINING THE EXACT LOCATIONS OF ALL EXISTING AND NEW EQUIPMENT.
  - D. NEW NETWORK FIRE ALARM CONTROL PANELS SHALL BE CONNECTED WITH A NEW FIBER OPTIC PATHWAY INSTALLED IN CONDUIT AND ARRANGED FOR DATA AND VOICE COMMUNICATION.
  - E. THE EXISTING FIRE ALARM NETWORK IS AN EDWARDS IRCD MULTIPLEX FIRE ALARM SYSTEM UTILIZING ANALOG ADDRESSABLE SIGNALING LINE CIRCUIT TECHNOLOGY. EXISTING ANALOG ADDRESSABLE INITIATING DEVICES, SIGNALING LINE CIRCUIT WIRING, NOTIFICATION APPLIANCES, NOTIFICATION APPLIANCE WIRING, AND CONTROL CIRCUIT WIRING SHALL REMAIN AND CONNECT TO NEW FIRE ALARM CONTROL PANELS. NEW FIRE ALARM CONTROL PANELS SHALL BE ARRANGED FOR COMPATIBILITY WITH EXISTING DEVICES, APPLIANCE AND CONTROL CIRCUITS. REFER TO SPECIFICATIONS FOR ADDITIONAL DETAILS.
  - F. EXISTING NOTIFICATION APPLIANCE SIGNALING IS ACCOMPLISHED WITH CONVENTIONAL HORN/STROBES AND SHALL REMAIN. THE NEW NETWORK FIRE ALARM SYSTEM SHALL BE ARRANGED WITH CONNECTIONS AND COMPONENTS FOR A FUTURE UPGRADE TO DIGITAL EMERGENCY VOICE/ALARM COMMUNICATIONS AS REQUIRED BY THE SPECIFICATIONS.
  - G. THE CONTRACTOR SHALL PROVIDE, INSTALL AND CONNECT NEW CONDUIT AND WIRING FOR A COMPLETE SYSTEM. ALL ABANDONED FIRE ALARM WIRING AND RACEWAY SHALL BE REMOVED.
  - H. SEE SPECIFICATIONS FOR INITIATING DEVICE, NOTIFICATION APPLIANCE CIRCUIT AND CONTROL CIRCUIT SCHEDULES FOR EXISTING FIRE ALARM CONTROL PANELS.
  - I. SEE SPECIFICATIONS FOR PHASING AND IMPAIRMENT REQUIREMENTS.

- PLAN NOTES**
- ① DEMOLISH EXISTING FIRE ALARM CONTROL PANEL AND POWER SUPPLIES.
  - ② DEMOLISH EXISTING FIRE ALARM CONTROL PANEL CIRCUITS COMPLETE BACK TO SOURCE. REMOVE CIRCUIT BREAKER LOCK AND PROVIDE NEW TYPED PANEL DIRECTORY.

**BUILDING 51 FIRE ALARM PLAN - SUB BASEMENT**  
1/8"=1'-0"

**100% Construction Documents - For Construction**

<b>REVISION</b>		<b>DATE</b>	
No			

<b>FP&amp;C Consultants, Inc.</b> 3770 Broadway Kansas City, MO 64111 816.931.3377 www.fpc-consultants.com	<b>Design Tree</b> ENGINEERING AND LAND SURVEYING Alexandria Office 120 17th Avenue W. Alexandria, MN 56308 (320) 762-1290 St. Cloud Office 3339 Witz St. Germantown, Suite 250 St. Cloud, MN 56301 (320) 217-5557
--	--

<b>JLG architects</b> Alexandria 525 Broadway Street Alexandria, MN 56302 phone 320.755.9903 facsimile 320.755.9906 www.jlgarchitects.com copyright © 2013	
---	--

DRAWING TITLE <b>BUILDING 51 FIRE ALARM PLAN - SUB BASEMENT</b>		PROJECT TITLE <b>FIRE ALARM REPLACEMENT</b>	
APPROVED: PROJECT DIRECTOR	DATE:	DESIGNED BY: <b>AS NOTED</b>	PROJECTED BY: <b>HHB</b>
		CHECKED BY: <b>CAB</b>	DATE FILED: <b>XXX</b>
		PROJECT: <b>ST. CLOUD VA MEDICAL CENTER ST. CLOUD, MN 56303</b>	
		DRAWING NO.: <b>FA1005-51</b>	

<b>St. Cloud VA Health Care System</b> Brainerd   Montevideo   Alexandria	
--	--